

# Lead Sample Test Results and Actions

## GIANT SPRINGS ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ( $\mu\text{g/L}$ ) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 001		No				
FX 002	Fountain Room 7	Yes	0.0009			No action
FX 003		No				
FX 004		No				
FX 005	Fountain Room 5	Yes	0.0009			No action
FX 006		No				
FX 007		No				
FX 008	Fountain Room 3	Yes	0.0009			No action
FX 009		No				
FX 010		No				
FX 011	Fountain Room 1	Yes	0.0009			No action
FX 012		No				
FX 013		No				
FX 014	Fountain Room 2	Yes	0.0009			No action
FX 015		No				
FX 016		No				
FX 017	Fountain Room 4	Yes	0.0009			No action
FX 018		No				
FX 019		No				
FX 020	Fountain Room 6	Yes	0.0009			No action
FX 021		No				
FX 022		No				
FX 023	Fountain Room 8	Yes	0.0009			No action
FX 024		No				
FX 025		No				
FX 026		No				
FX 027		No				
FX 028	Fountain Room 12	Yes	0.0009			No action
FX 029		No				
FX 030	Fountain Room 14	Yes	0.0009			No action
FX 031		No				
FX 032	Fountain Room 15	Yes	0.0009			No action
FX 033		No				
FX 034	Fountain Room 13	Yes	0.0009			No action
FX 035		No				
FX 036	Fountain Room 11	Yes	0.0009			No action

# Lead Sample Test Results and Actions

## GIANT SPRINGS ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ( $\mu\text{g/L}$ ) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 037		No				
FX 038	Fountain Room 9	Yes	0.0009			No action
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044	Hi fountain 1st floor	Yes	0.0009			No action
FX 045	Bottle filler 1st floor	Yes	0.0009			No action
FX 046	Low fountain 1st floor	Yes	0.0009			No action
FX 047		No				
FX 048		No				
FX 049		No				
FX 050		No				
FX 051		No				
FX 052	Kitchen hand sink	Yes	0.0009			No action
FX 053	Kitchen hand sink	Yes	0.0009			No action
FX 054	Kitchen sink	Yes	0.0009			No action
FX 055	Kitchen sink	Yes	0.0009			No action
FX 056	Kitchen sink	Yes	0.0009			No action
FX 057		No				
FX 058	Hi fountain cafeteria	Yes	0.0009			No action
FX 059	Bottle filler cafeteria	Yes	0.0009			No action
FX 060	Low fountain cafeteria	Yes	0.0009			No action
FX 061		No				
FX 062		No				
FX 063		No				
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				
FX 069	Fountain Room 23	Yes	0.0009			No action
FX 070		No				
FX 071	Fountain Room 21	Yes	0.0009			No action
FX 072		No				

# Lead Sample Test Results and Actions

## GIANT SPRINGS ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ( $\mu\text{g/L}$ ) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 073		No				
FX 074		No				
FX 075		No				
FX 076	Fountain Room 19	Yes	0.0009			No action
FX 077		No				
FX 078	Fountain Room 17	Yes	0.0009			No action
FX 079		No				
FX 080	Fountain Room 16	Yes	0.0009			No action
FX 081		No				
FX 082	Fountain Room 18	Yes	0.0009			No action
FX 083		No				
FX 084	Fountain Room 20	Yes	0.0009			No action
FX 085		No				
FX 086	Fountain Room 22	Yes	0.0009			No action
FX 087		No				
FX 088		No				
FX 089		No				
FX 090		No				
FX 091		No				
FX 092	Fountain Room 29	Yes	0.0009			No action
FX 093		No				
FX 094	Fountain Room 27	Yes	0.0009			No action
FX 095		No				
FX 096		No				
FX 097		No				
FX 098		No				
FX 099		No				
FX 100	Hi fountain 2nd floor	Yes	0.0009			No action
FX 101	Bottle filler 2nd floor	Yes	0.0009			No action
FX 102	Low fountain 2nd floor	Yes	0.0009			No action