

Lead Sample Test Results and Actions

LOY ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007	Rm 26 fountain	Yes	0.0009			No action
FX 008		No				
FX 009	Rm 25 fountain	Yes	0.001			No action
FX 010		No				
FX 011	Rm 24 fountain	Yes	0.0009			No action
FX 012		No				
FX 013	Rm 23 fountain	Yes	0.002			No action
FX 014		No				
FX 015	Rm 22 fountain	Yes	0.002			No action
FX 016	Rm 21 sink	Yes	0.0009			No action
FX 017		No				
FX 018		No				
FX 019	Rm 20 fountain	Yes	0.0009			No action
FX 020		No				
FX 021		No				
FX 022		No				
FX 023	Rm 18 fountain	Yes	0.0009			No action
FX 024		No				
FX 025	Rm 17 fountain	Yes	0.0009			No action
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030	Rm 1 fountain	Yes	0.001			No action
FX 031		No				
FX 032	Rm 2 fountain	Yes	0.001			No action
FX 033		No				
FX 034	Rm 3 fountain	Yes	0.001			No action
FX 035		No				

Lead Sample Test Results and Actions

LOY ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter ($\mu\text{g/L}$) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 $\mu\text{g/L}$ less than 15.0 $\mu\text{g/L}$ – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 $\mu\text{g/L}$ – no action is required.
FX 036	Rm 4 fountain	Yes	0.0009			No action
FX 037		No				
FX 038	Rm 5 fountain	Yes	0.0009			No action
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045		No				
FX 046		No				
FX 047		No				
FX 048	Fountain by Rm 6	Yes	0.0009			No action
FX 049	Bottle filler by Rm 6	Yes	0.0009			No action
FX 050	Fountain by Rm 6 porc.	Yes	0.002			No action
FX 051		No				
FX 052	Rm 6 fountain	Yes	0.002			No action
FX 053		No				
FX 054	Rm 7 fountain	Yes	0.002			No action
FX 055		No				
FX 056	Rm 8 fountain	Yes	0.0009			No action
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				
FX 062		No				
FX 063		No				
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068	Fountain by Rm 9	Yes	0.0009			No action
FX 069	Bottle filler by Rm 9	Yes	0.0009			No action
FX 070	Fountain by girls restrm	Yes	0.0009			No action
FX 071		No				

Lead Sample Test Results and Actions

LOY ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 072	Rm 9 fountain	Yes	0.002			No action
FX 073		No				
FX 074	Rm 10 Fountain	Yes	0.0009			No action
FX 075		No				
FX 076	Rm 11 fountain	Yes	0.001			No action
FX 077		No				
FX 078	Rm 12 fountain	Yes	0.001			No action
FX 079		No				
FX 080	Rm 13 Fountain	Yes	0.0009			No action
FX 081		No				
FX 082	Rm 14 fountain	Yes	0.001			No action
FX 083		No				
FX 084	Rm 15 fountain	Yes	0.003			No action
FX 085		No				
FX 086	Rm 16 Fountain	Yes	0.0009			No action
FX 087		No				
FX 088		No				
FX 089	Kitchen sink	Yes	0.0009			No action
FX 090		No				
FX 091	Kitchen sprayer	Yes	0.0009			No action
FX 092	PTA kitchen sink	Yes	0.0009			No action
FX 093	Fountain by gym low	Yes	0.002			No action
FX 094	Fountain by gym high	Yes	0.002			No action