

# Lead Sample Test Results and Actions

## MEADOW LARK ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004	Kitchen	Yes	0.0009			No action
FX 005	Kitchen sprayer	Yes	0.0009			No action
FX 006		No				
FX 007	Cafeteria fountain	Yes	0.0009			No action
FX 008		No				
FX 009	West hall fountain hi	Yes	0.0009			No action
FX 010	West hall fountain low	Yes	0.0009			No action
FX 011		No				
FX 012		No				
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017	Rm B1 fountain	Yes	0.001			No action
FX 018		No				
FX 019	Rm B2 fountain	Yes	0.0009			No action
FX 020		No				
FX 021	Rm B3 fountain	Yes	0.001			No action
FX 022		No				
FX 023	Rm B4 fountain	Yes	0.0009			No action
FX 024		No				
FX 025	Rm B5 fountain	Yes	0.001			No action
FX 026		No				
FX 027	Rm B6 fountain	Yes	0.001			No action
FX 028		No				
FX 029	Rm C6 fountain	Yes	0.001			No action
FX 030		No				
FX 031	Rm C5 fountain	Yes	0.001			No action
FX 032		No				
FX 033	Rm C4 fountain	Yes	0.0009			No action
FX 034		No				
FX 035	Rm C3 fountain	Yes	0.0009			No action
FX 036		No				

## Lead Sample Test Results and Actions

### MEADOW LARK ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 037	Rm C2 fountain	Yes	0.0009			No action
FX 038		No				
FX 039	Rm C1 fountain	Yes	0.0009			No action
FX 040		No				
FX 041	Rm K1 fountain	Yes	0.001			No action
FX 042		No				
FX 043	Rm A9 fountain	Yes	0.0009			No action
FX 044		No				
FX 045		No				
FX 046	Rm K2 fountain	Yes	0.001			No action
FX 047	Rm K3 fountain	Yes	0.0009			No action
FX 048		No				
FX 049	Rm A1 fountain	Yes	0.0009			No action
FX 050		No				
FX 051	Rm A2 fountain	Yes	0.0009			No action
FX 052		No				
FX 053	Rm A3 fountain	Yes	0.0009			No action
FX 054		No				
FX 055	Rm A4 fountain	Yes	0.0009			No action
FX 056		No				
FX 057	Rm A5 fountain	Yes	0.001			No action
FX 058		No				
FX 059	Rm A6 fountain	Yes	0.0009			No action
FX 060		No				
FX 061		No				
FX 062	Rm A7 fountain	Yes	0.0009			No action
FX 063		No				
FX 064	Rm A8 fountain	Yes	0.0009			No action
FX 065		No				
FX 066	East hall fountain hi	Yes	0.0009			No action
FX 067	East hall fountain low	Yes	0.0009			No action
FX 068	East hall bottle filler	Yes	0.0009			No action